


(74) Agent: MACRAE & CO.

(54) Title: PREDICTIVE MAINTENANCE AND EQUIPMENT MONITORING FOR A REFRIGERATION SYSTEM



A system for monitoring a remote refrigeration system (100) includes a plurality of sensors (114, 118, 124, 128) that monitor parameters of components of the refrigeration system (100) and a communication network (161) that transfers signals generated

(57) **Abrégé(suite)/Abstract(continued):**

by each of the plurality of sensors. A management center (160) receives the signals from the communication network (161) and processes the signals to determine an operating condition of at least one of the components. The management center (160) generates an alarm based on the operating condition.

(12) INTERNATIONAL APPLICATION PUBLISHED UNDER THE PATENT COOPERATION TREATY (PCT)

(19) World Intellectual Property
Organization
International Bureau



(43) International Publication Date
18 November 2004 (18.11.2004)

PCT

(10) International Publication Number
WO 2004/099683 A3

(51) International Patent Classification⁷: **F25B 49/02**

(21) International Application Number:
PCT/US2004/013384

(22) International Filing Date: 29 April 2004 (29.04.2004)

(25) Filing Language: English

(26) Publication Language: English

(30) Priority Data:
60/466,637 30 April 2003 (30.04.2003) US
10/833,259 27 April 2004 (27.04.2004) US

(63) Related by continuation (CON) or continuation-in-part (CIP) to earlier application:
US 10/833,259 (CON)
Filed on 27 April 2004 (27.04.2004)

(71) Applicant (for all designated States except US): **EMERSON RETAIL SERVICES INC.** [US/US]; 1640 Airport Road NW, Suite 105, Kennesaw, GA 30144 (US).

(72) Inventors; and

(75) Inventors/Applicants (for US only): **SINGH, Abtar**

[IN/US]; 2948 Monrovia Trail, Kennesaw, GA 30144 (US). **MATHEWS, Thomas, J.** [US/US]; RR#1, Box 3643, Lovejoy Pond Road, Fayette, ME 04349 (US). **WOODWORTH, Stephen, T.** [US/US]; 308 Woodknoll Court, Woodstock, GA 30189 (US).


(74) Agents: **EUSEBI, Christopher, A.** et al.; Harness, Dickey & Pierce, P.L.C., P.O. Box 838, Bloomfield Hills, MI 48303 (US).

(81) Designated States (unless otherwise indicated, for every kind of national protection available): AE, AG, AL, AM, AT, AU, AZ, BA, BB, BG, BR, BW, BY, BZ, CA, CH, CN, CO, CR, CU, CZ, DE, DK, DM, DZ, EC, EE, EG, ES, FI, GB, GD, GE, GH, GM, HR, HU, ID, IL, IN, IS, JP, KE, KG, KP, KR, KZ, LC, LK, LR, LS, LT, LU, LV, MA, MD, MG, MK, MN, MW, MX, MZ, NA, NI, NO, NZ, OM, PG, PH, PL, PT, RO, RU, SC, SD, SE, SG, SK, SL, SY, TJ, TM, TN, TR, TT, TZ, UA, UG, US (patent), UZ, VC, VN, YU, ZA, ZM, ZW.

(84) Designated States (unless otherwise indicated, for every kind of regional protection available): ARIPO (BW, GH, GM, KE, LS, MW, MZ, NA, SD, SL, SZ, TZ, UG, ZM, ZW), Eurasian (AM, AZ, BY, KG, KZ, MD, RU, TJ, TM),

[Continued on next page]

(54) Title: PREDICTIVE MAINTAINANCE AND EQUIPMENT MONITORING FOR A REFRIGERATION SYSTEM



(57) Abstract: A system for monitoring a remote refrigeration system (100) includes a plurality of sensors (114, 118, 124, 128) that monitor parameters of components of the refrigeration system (100) and a communication network (161) that transfers signals generated by each of the plurality of sensors. A management center (160) receives the signals from the communication network (161) and processes the signals to determine an operating condition of at least one of the components. The management center (160) generates an alarm based on the operating condition.

WO 2004/099683 A3

WO 2004/099683 A3

European (AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HU, IE, IT, LU, MC, NL, PL, PT, RO, SE, SI, SK, TR), OAPI (BF, BJ, CF, CG, CI, CM, GA, GN, GQ, GW, ML, MR, NE, SN, TD, TG).

IT, LU, MC, NL, PL, PT, RO, SE, SI, SK, TR), OAPI patent (BF, BJ, CF, CG, CI, CM, GA, GN, GQ, GW, ML, MR, NE, SN, TD, TG)

- as to the applicant's entitlement to claim the priority of the earlier application (Rule 4.17(iii)) for all designations
- of inventorship (Rule 4.17(iv)) for US only

Declarations under Rule 4.17:

- as to applicant's entitlement to apply for and be granted a patent (Rule 4.17(ii)) for the following designations AE, AG, AL, AM, AT, AU, AZ, BA, BB, BG, BR, BW, BY, BZ, CA, CH, CN, CO, CR, CU, CZ, DE, DK, DM, DZ, EC, EE, EG, ES, FI, GB, GD, GE, GH, GM, HR, HU, ID, IL, IN, IS, JP, KE, KG, KP, KR, KZ, LC, LK, LR, LS, LT, LU, LV, MA, MD, MG, MK, MN, MW, MX, MZ, NA, NI, NO, NZ, OM, PG, PH, PL, PT, RO, RU, SC, SD, SE, SG, SK, SL, SY, TJ, TM, TN, TR, TT, TZ, UA, UG, UZ, VC, VN, YU, ZA, ZM, ZW, ARIPO patent (BW, GH, GM, KE, LS, MW, MZ, NA, SD, SL, SZ, TZ, UG, ZM, ZW), Eurasian patent (AM, AZ, BY, KG, KZ, MD, RU, TJ, TM), European patent (AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HU, IE,

Published:

- with international search report
- with amended claims

(88) Date of publication of the international search report:

16 December 2004

Date of publication of the amended claims: 17 February 2005

For two-letter codes and other abbreviations, refer to the "Guidance Notes on Codes and Abbreviations" appearing at the beginning of each regular issue of the PCT Gazette.

PREDICTIVE MAINTENANCE AND EQUIPMENT MONITORING FOR A REFRIGERATION SYSTEM

CROSS-REFERENCE TO RELATED APPLICATIONS

[0001] This application claims the benefit of U.S. Provisional Application No. 60/466,637, filed on April 20, 2003. The disclosure of the above application is incorporated herein by reference.

5 FIELD OF THE INVENTION

[0002] The present invention relates to refrigeration systems and more particularly to predictive maintenance and equipment monitoring of a refrigeration system.

10 BACKGROUND OF THE INVENTION

[0003] Produced food travels from processing plants to retailers, where the food product remains on display case shelves for extended periods of time. In general, the display case shelves are part of a refrigeration system for storing the food product. In the interest of efficiency, retailers attempt to
15 maximize the shelf-life of the stored food product while maintaining awareness of food product quality and safety issues.

[0004] The refrigeration system plays a key role in controlling the quality and safety of the food product. Thus, any breakdown in the refrigeration system or variation in performance of the refrigeration system
20 can cause food quality and safety issues. Thus, it is important for the retailer to monitor and maintain the equipment of the refrigeration system to ensure its operation at expected levels.

[0005] Refrigeration systems generally require a significant amount of energy to operate. The energy requirements are thus a significant cost to
25 food product retailers, especially when compounding the energy uses across multiple retail locations. As a result, it is in the best interest of food retailers to closely monitor the performance of the refrigeration systems to maximize their efficiency, thereby reducing operational costs.

[0006] Monitoring refrigeration system performance, maintenance
30 and energy consumption are tedious and time-consuming operations and are

undesirable for retailers to perform independently. Generally speaking, retailers lack the expertise to accurately analyze time and temperature data and relate that data to food product quality and safety, as well as the expertise to monitor the refrigeration system for performance, maintenance and efficiency. Further, a typical food retailer includes a plurality of retail locations spanning a large area. Monitoring each of the retail locations on an individual basis is inefficient and often results in redundancies.

SUMMARY OF THE INVENTION

10 **[0007]** Accordingly, the present invention provides a system for monitoring a remote refrigeration system. The system includes a plurality of sensors that monitor parameters of components of the refrigeration system and a communication network that transfers signals generated by each of the plurality of sensors. A management center receives the signals from the communication network and processes the signals to determine an operating condition of at least one of the components. The management center generates an alarm based on the operating condition.

15 **[0008]** In one feature, the management center evaluates each of the signals to determine whether each of the signals is within a useful range, to determine whether each of the signals is dynamic and to determine whether each of the signals is valid.

20 **[0009]** In other features, the system further includes a temperature sensor monitors a temperature of a refrigerant flowing through the refrigeration system and generates a temperature signal. The management center calculates a pressure, a density and an enthalpy of the refrigerant based on the temperature and based on whether the refrigerant is in one of a saturated liquid phase and a saturated vapor phase.

25 **[0010]** In other features, the system further includes a pressure sensor that monitors a pressure of a refrigerant flowing through the refrigeration system and that generates a pressure signal. The management center calculates a temperature, a density and an enthalpy of the refrigerant based on said pressure and based on whether the refrigerant is in one of a saturated liquid phase and a saturated vapor phase.

[0011] In other features, the system further includes a temperature sensor that monitors a temperature of a refrigerant at a suction side of a compressor of the refrigeration system and generates a temperature signal. A pressure sensor monitors a pressure of a refrigerant at the suction side of the compressor and generates a pressure signal. The management center determines an occurrence of a floodback event based on the temperature signal and the pressure signal. The management center determines a superheat temperature of the refrigerant based on the temperature signal and the pressure signal and processes the superheat through a pattern analyzer to determine whether the floodback event has occurred.

[0012] In still other features, the system further includes a temperature sensor that monitors a temperature of a refrigerant at a discharge side of a compressor of the refrigeration system and that generates a temperature signal. A pressure sensor monitors a pressure of a refrigerant at the discharge side of the compressor and generates a pressure signal. The management center determines an occurrence of a floodback event based on the temperature signal and the pressure signal. The management center determines a superheat temperature of the refrigerant based on the temperature signal and the pressure signal and processes the superheat through a pattern analyzer to determine whether the floodback event has occurred.

[0013] In yet other features, the system further includes a contactor associated with one of the components. The contactor is cycled between an open position and a closed position to selectively operate the component. The management center monitors cycling of the contactor and generates an alarm when one of a cycling rate is exceeded and a maximum number of cycles is exceeded.

[0014] In still another feature, the system further includes an ambient condenser temperature sensor that generates an ambient temperature signal, a condenser pressure sensor that generates a pressure signal, a compressor current sensor that generates a compressor current signal and a condenser current sensor that generates a condenser current signal. The management center determines an operating condition of the

condenser based on the ambient temperature signal, the pressure signal, the compressor current signal and the condenser current signal.

5 [0015] In yet another feature, the system further includes a discharge pressure sensor that monitors a pressure of a refrigerant at a discharge side of the compressor and that generates a discharge pressure signal. A suction pressure sensor monitors a pressure of a refrigerant at a suction side of the compressor and generates a suction pressure signal. The management center determines loss of refrigerant based on the discharge pressure and the suction pressure.

10

BRIEF DESCRIPTION OF THE DRAWINGS

[0016] The present invention will become more fully understood from the detailed description and the accompanying drawings, wherein:

15 [0017] Figure 1 is a schematic illustration of an exemplary refrigeration system;

[0018] Figure 2 is a schematic overview of a system for remotely monitoring and evaluating a remote location;

[0019] Figure 3 is a simplified schematic illustration of circuit piping of the refrigeration system of Figure 1 illustrating measurement sensors;

20 [0020] Figure 4 is a simplified schematic illustration of loop piping of the refrigeration system of Figure 1 illustrating measurement sensors;

[0021] Figure 5 is a flowchart illustrating a signal conversion and validation algorithm according to the present invention;

25 [0022] Figure 6 is a block diagram illustrating configuration and output parameters for the signal conversion and validation algorithm of Figure 5;

[0023] Figure 7 is a flowchart illustrating a refrigerant properties from temperature (RPFT) algorithm;

30 [0024] Figure 8 is a block diagram illustrating configuration and output parameters for the RPFT algorithm;

[0025] Figure 9 is a flowchart illustrating a refrigerant properties from pressure (RPFP) algorithm;

[0026] Figure 10 is a block diagram illustrating configuration and output parameters for the RPFP algorithm;

[0027] Figure 11 is a block diagram illustrating configuration and output parameters of a watchdog message algorithm;

[0028] Figure 12 is a block diagram illustrating configuration and output parameters of a recurring alarm algorithm;

5 [0029] Figure 13 is a block diagram illustrating configuration and output parameters of a superheat monitor algorithm;

[0030] Figure 14 is a flowchart illustrating a suction flood back alert algorithm;

10 [0031] Figure 15 is a flowchart illustrating a discharge flood back alert algorithm;

[0032] Figure 16 is a block diagram illustrating configuration and output parameters of a contactor cycle monitoring algorithm;

[0033] Figure 17 is a flowchart illustrating the contactor cycle monitoring algorithm;

15 [0034] Figure 18 is a block diagram illustrating configuration and output parameters of a compressor performance monitor;

[0035] Figure 19 is a flowchart illustrating a compressor fault detection algorithm;

20 [0036] Figure 20 is a block diagram illustrating configuration and output parameters of a condenser performance monitor;

[0037] Figure 21 is a flowchart illustrating a condenser performance algorithm;

[0038] Figure 22 is a graph illustrating pattern bands of the pattern recognition algorithm

25 [0039] Figure 23 is a block diagram illustrating configuration and output parameters of a pattern analyzer; and

[0040] Figure 24 is a flowchart illustrating a pattern recognition algorithm.

30 DETAILED DESCRIPTION OF THE PREFERRED EMBODIMENTS

[0041] The following description of the preferred embodiments is merely exemplary in nature and is in no way intended to limit the invention, its application, or uses.

[0042] With reference to Figure 1, an exemplary refrigeration system 100 includes a plurality of refrigerated food storage cases 102. The refrigeration system 100 includes a plurality of compressors 104 piped together with a common suction manifold 106 and a discharge header 108 all positioned within a compressor rack 110. A discharge output 112 of each compressor 102 includes a respective temperature sensor 114. An input 116 to the suction manifold 106 includes both a pressure sensor 118 and a temperature sensor 120. Further, a discharge outlet 122 of the discharge header 108 includes an associated pressure sensor 124. As described in further detail hereinbelow, the various sensors are implemented for evaluating maintenance requirements.

[0043] The compressor rack 110 compresses refrigerant vapor that is delivered to a condenser 126 where the refrigerant vapor is liquefied at high pressure. Condenser fans 127 are associated with the condenser 126 to enable improved heat transfer from the condenser 126. The condenser 126 includes an associated ambient temperature sensor 128 and an outlet pressure sensor 130. This high-pressure liquid refrigerant is delivered to the plurality of refrigeration cases 102 by way of piping 132. Each refrigeration case 102 is arranged in separate circuits consisting of a plurality of refrigeration cases 102 that operate within a certain temperature range. Figure 1 illustrates four (4) circuits labeled circuit A, circuit B, circuit C and circuit D. Each circuit is shown consisting of four (4) refrigeration cases 102. However, those skilled in the art will recognize that any number of circuits, as well as any number of refrigeration cases 102 may be employed within a circuit. As indicated, each circuit will generally operate within a certain temperature range. For example, circuit A may be for frozen food, circuit B may be for dairy, circuit C may be for meat, etc.

[0044] Because the temperature requirement is different for each circuit, each circuit includes a pressure regulator 134 that acts to control the evaporator pressure and, hence, the temperature of the refrigerated space in the refrigeration cases 102. The pressure regulators 134 can be electronically or mechanically controlled. Each refrigeration case 102 also includes its own evaporator 136 and its own expansion valve 138 that may be either a mechanical or an electronic valve for controlling the superheat of the refrigerant. In this regard, refrigerant is delivered by piping to the evaporator 136 in each refrigeration case 102.

[0045] The refrigerant passes through the expansion valve 138 where a pressure drop causes the high pressure liquid refrigerant to achieve a lower pressure combination of liquid and vapor. As hot air from the refrigeration case 102 moves across the evaporator 136, the low pressure liquid turns into gas. 5 This low pressure gas is delivered to the pressure regulator 134 associated with that particular circuit. At the pressure regulator 134, the pressure is dropped as the gas returns to the compressor rack 110. At the compressor rack 110, the low pressure gas is again compressed to a high pressure gas, which is delivered to the condenser 126, which creates a high pressure liquid to supply to 10 the expansion valve 138 and start the refrigeration cycle again.

[0046] A main refrigeration controller 140 is used and configured or programmed to control the operation of the refrigeration system 100. The refrigeration controller 140 is preferably an Einstein Area Controller offered by CPC, Inc. of Atlanta, Georgia, or any other type of programmable controller that 15 may be programmed, as discussed herein. The refrigeration controller 140 controls the bank of compressors 104 in the compressor rack 110, via an input/output module 142. The input/output module 142 has relay switches to turn the compressors 104 on an off to provide the desired suction pressure.

[0047] A separate case controller (not shown), such as a CC-100 20 case controller, also offered by CPC, Inc. of Atlanta, Georgia may be used to control the superheat of the refrigerant to each refrigeration case 102, via an electronic expansion valve in each refrigeration case 102 by way of a communication network or bus. Alternatively, a mechanical expansion valve may be used in place of the separate case controller. Should separate case 25 controllers be utilized, the main refrigeration controller 140 may be used to configure each separate case controller, also via the communication bus. The communication bus may either be a RS-485 communication bus or a LonWorks Echelon bus that enables the main refrigeration controller 140 and the separate case controllers to receive information from each refrigeration case 102.

30 [0048] Each refrigeration case 102 may have a temperature sensor 146 associated therewith, as shown for circuit B. The temperature sensor 146 can be electronically or wirelessly connected to the controller 140 or the expansion valve for the refrigeration case 102. Each refrigeration case 102 in the circuit B may have a separate temperature sensor 146 to take

average/min/max temperatures or a single temperature sensor 146 in one refrigeration case 102 within circuit B may be used to control each refrigeration case 102 in circuit B because all of the refrigeration cases 102 in a given circuit operate at substantially the same temperature range. These temperature inputs
5 are preferably provided to the analog input board 142, which returns the information to the main refrigeration controller 140 via the communication bus.

[0049] Additionally, further sensors are provided and correspond with each component of the refrigeration system and are in communication with the refrigeration controller 140. Energy sensors 150 are associated with the
10 compressors 104 and the condenser 126 of the refrigeration system 100. The energy sensors 150 monitor energy consumption of their respective components and relay that information to the controller 140.

[0050] Referring now to Figure 2, the refrigeration controller 140 and case controllers communicates with a remote network or processing center 160.
15 It is anticipated that the remote processing center 160 can be either in the same location (e.g. food product retailer) as the refrigeration system 100 or can be a centralized processing center that monitors the refrigeration systems of several remote locations. The refrigeration controller 140 and case controllers initially communicate with a site-based controller 161 via a serial connection or
20 Ethernet. The site-based controller 161 communicates with the processing center 160 via a TCP/IP connection.

[0051] The processing center 160 collects data from the refrigeration controller 140, the case controllers and the various sensors associated with the refrigeration system 100. For example, the processing
25 center 160 collects information such as compressor, flow regulator and expansion valve set points from the refrigeration controller 140. Data such as pressure and temperature values at various points along the refrigeration circuit are provided by the various sensors via the refrigeration controller 140. More specifically, the software system is a multi-tiered system spanning all
30 three hardware levels. At the local level (i.e., refrigeration controller and case controllers) is the existing controller software and raw I/O data collection and conversion.

[0052] A controller database and the ProAct CB algorithms reside on the site-based controller 161. The algorithms manipulate the controller

data generating notices, service recommendations, and alarms based on pattern recognition and fuzzy logic. Finally, this algorithm output (alarms, notices, etc.) is served to a remote network workstation at the processing center 160, where the actual service calls are dispatched and alarms
5 managed. The refined data is archived for future analysis and customer access at a client-dedicated website.

[0053] Referring now to Figures 3 and 4, for each refrigeration circuit and loop of the refrigeration system 100, several calculations are required to calculate superheat, saturation properties and other values used in
10 the hereindescribed algorithms. These measurements include: ambient temperature (T_a), discharge pressure (P_d), condenser pressure (P_c), suction temperature (T_s), suction pressure (P_s), refrigeration level (L_{REF}), compressor discharge temperature (T_d), rack current load (I_{comp}), condenser current load (I_{cnd}) and compressor run status. Other accessible controller parameters will
15 be used as necessary. For example, a power sensor can monitor the power consumption of the compressor racks and the condenser. Besides the sensors described above, suction temperature sensors 115 monitor T_s of the individual compressors 104 in a rack and a rack current sensor 150 monitors I_{comp} of a rack. The pressure sensor 124 monitors P_d and a current sensor 127
20 monitors I_{cnd} . Multiple temperature sensors 129 monitor a return temperature (T_c) for each circuit.

[0054] The present invention provides control and evaluation algorithms in the form of software modules to predict maintenance requirements for the various components in the refrigeration system 100.
25 These algorithms include signal conversion and validation, saturated refrigerant properties, watchdog message, recurring notice or alarm message, flood back alert, contactor cycling count, compressor performance, condenser performance, defrost abnormality, case discharge versus product temperature, data pattern recognition, condenser discharge temperature and
30 loss of refrigerant charge. Each is discussed in detail below. The algorithms can be processed locally using the refrigeration controller 140 or remotely at the remote processing center 160.

[0055] Referring now to Figures 5, a signal conversion and validation (SCV) algorithm processes measurement signals from the various

sensors. The SCV algorithm determines the value of a particular signal and up to three different qualities including whether the signal is within a useful range, whether the signal changes over time and/or whether the actual input signal from the sensor is valid.

5 **[0056]** In step 500, the input registers read the measurement signal of a particular sensor. In step 502, it is determined whether the input signal is within a range that is particular to the type of measurement. If the input signal is within range, the SCV algorithm continues in step 504. If the input signal is not within the range an invalid data range flag is set in step 506 and the SCV
10 algorithm continues in step 508. In step 504, it is determined whether there is a change (Δ) in the signal within a threshold time (t_{thresh}). If there is no change in the signal it is deemed static. In this case, a static data value flag is set in step 510 and the SCV algorithm continues in step 508. If there is a change in the signal a valid data value flag is set in step 512 and the SCV algorithm
15 continues in step 508.

[0057] In step 508, the signal is converted to provide finished data. More particularly, the signal is generally provided as a voltage. The voltage corresponds to a particular value (e.g., temperature, pressure, current, etc.). Generally, the signal is converted by multiplying the voltage value by a
20 conversion constant (e.g., $^{\circ}\text{C}/\text{V}$, kPa/V , A/V , etc.). In step 514, the output registers pass the data value and validation flags and control ends.

[0058] Referring now to Figure 6, a block diagram schematically illustrates an SCV block 600. A measured variable 602 is shown as the input signal. The input signal is provided by the instruments or sensors.
25 Configuration parameters 604 are provided and include Lo and Hi range values, a time Δ , a signal Δ and an input type. The configuration parameters 604 are specific to each signal and each application. Output parameters 606 are output by the SCV block 600 and include the data value, bad signal flag, out of range flag and static value flag. In other words, the output parameters
30 606 are the finished data and data quality parameters associated with the measured variable.

[0059] Referring now to Figures 7 through 10, refrigeration property algorithms will be described in detail. The refrigeration property algorithms provide the saturation pressure (P_{SAT}), density and enthalpy based on

temperature. The refrigeration property algorithms further provide saturation temperature (T_{SAT}) based on pressure. Each algorithm incorporates thermal property curves for common refrigerant types including, but not limited to, R22, R401a (MP39), R402a (HP80), R404a (HP62), R409a and R507c.

5 **[0060]** With particular reference to Figure 7 a refrigerant properties from temperature (RPFT) algorithm is shown. In step 700, the temperature and refrigerant type are input. In step 702, it is determined whether the refrigerant is saturated liquid based on the temperature. If the refrigerant is in the saturated liquid state, the RPFT algorithm continues in step 704. If the
10 refrigerant is not in the saturated liquid state, the RPFT algorithm continues in step 706. In step 704, the RPFT algorithm selects the saturated liquid curve from the thermal property curves for the particular refrigerant type and continues in step 708.

[0061] In step 706, it is determined whether the refrigerant is in a
15 saturated vapor state. If the refrigerant is in the saturated vapor state, the RPFT algorithm continues in step 710. If the refrigerant is not in the saturated vapor state, the RPFT algorithm continues in step 712. In step 712, the data values are cleared, flags are set and the RPFT algorithm continues in step 714. In step 710, the RPFT algorithm selects the saturated vapor curve from
20 the thermal property curves for the particular refrigerant type and continues in step 708. In step 708, data values for the refrigerant are determined. The data values include pressure, density and enthalpy. In step 714, the RPFT algorithm outputs the data values and flags.

[0062] Referring now to Figure 8, a block diagram schematically
25 illustrates an RPFT block 800. A measured variable 802 is shown as the temperature. The temperature is provided by the instruments or sensors. Configuration parameters 804 are provided and include the particular refrigerant type. Output parameters 806 are output by the RPFT block 800 and include the pressure, enthalpy, density and data quality flag.

30 **[0063]** With particular reference to Figure 9 a refrigerant properties from pressure (RPFP) algorithm is shown. In step 900, the temperature and refrigerant type are input. In step 902, it is determined whether the refrigerant is saturated liquid based on the pressure. If the refrigerant is in the saturated liquid state, the RPFP algorithm continues in step 904. If the refrigerant is not

in the saturated liquid state, the RPFP algorithm continues in step 906. In step 904, the RPFP algorithm selects the saturated liquid curve from the thermal property curves for the particular refrigerant type and continues in step 908.

5 **[0064]** In step 906, it is determined whether the refrigerant is in a saturated vapor state. If the refrigerant is in the saturated vapor state, the RPFP algorithm continues in step 910. If the refrigerant is not in the saturated vapor state, the RPFP algorithm continues in step 912. In step 912, the data values are cleared, flags are set and the RPFP algorithm continues in step 10 914. In step 910, the RPFP algorithm selects the saturated vapor curve from the thermal property curves for the particular refrigerant type and continues in step 908. In step 908, the temperature of the refrigerant is determined. In step 914, the RPFP algorithm outputs the temperature and flags.

[0065] Referring now to Figure 10, a block diagram schematically 15 illustrates an RPFP block 1000. A measured variable 1002 is shown as the pressure. The pressure is provided by the instruments or sensors. Configuration parameters 1004 are provided and include the particular refrigerant type. Output parameters 1006 are output by the RPFP block 1000 and include the temperature and data quality flag.

20 **[0066]** Referring now to Figure 11, a block diagram schematically illustrates the watchdog message algorithm, which includes a message generator 1100, configuration parameters 1102 and output parameters 1104. In accordance with the watchdog message algorithm, the site-based controller 161 periodically reports its health (i.e., operating condition) to the remainder of 25 the network. The site-based controller generates a test message that is periodically broadcast. The time and frequency of the message is configured by setting the time of the first message and the number of times per day the test message is to be broadcast. Other components of the network (e.g., the refrigeration controller 140, the processing center 160 and the case 30 controllers) periodically receive the test message. If the test message is not received by one or more of the other network components, a controller communication fault is indicated.

[0067] Referring now to Figure 12, a block diagram schematically illustrates the recurring notice or alarm message algorithm. The recurring

notice or alarm message algorithm monitors the state of signals generated by the various algorithms described herein. Some signals remain in the alarm state for a protracted period of time until the corresponding issue is resolved. As a result, an alarm message that is initially generated as the initial alarm
5 occurs may be overlooked later. The recurring notice/alarm message algorithm generates the alarm message at a configured frequency. The alarm message is continuously regenerated until the alarm condition is resolved.

[0068] The recurring notice or alarm message algorithm includes a notice/alarm message generator 1200, configuration parameters 1202, input
10 parameters 1204 and output parameters 1206. The configuration parameters 1202 include message frequency. The input 1204 includes a notice/alarm message and the output parameters 1206 include a regenerated notice/alarm message. The notice/alarm generator 1200 regenerates the input alarm message at the indicated frequency. Once the notice/alarm condition is
15 resolved, the input 1204 will indicate as such and regeneration of the notice/alarm message terminates.

[0069] Referring now to Figures 13 through 15, the flood back alert algorithm is described in detail. Liquid refrigerant flood back occurs when liquid refrigerant reverse migrates through the refrigeration system 100 from
20 the evaporator through to the compressor 102. The flood back alert algorithm monitors the superheat conditions of the refrigeration circuits A, B, C, D and both the compressor suction/discharge. The superheat is filtered through a pattern analyzer and an alarm is generated if the filtered superheat falls outside of a specified range. Superheat signals outside of the specified range
25 indicate a flood back event. In the case where multiple flood back events are indicated, a severe flood back alarm is generated.

[0070] The saturated vapor temperature for the compressor suction is calculated from the suction pressure. The superheat is calculated for each refrigeration and compressor by subtracting the return temperature from the
30 saturated vapor temperature. Similarly, assuming a saturated liquid, the superheat for each compressor discharge is calculated by subtracting the compressor discharge temperature from the discharge saturated liquid temperature.

[0071] Figure 13 provides a schematic illustration of a superheat monitor block 1300 that includes an RPFP module 1302 and a pattern analyzer module 1304. Measured variables 1306 include temperature and pressure and are input to the superheat monitor 1300. Configuration parameters 1308 include refrigerant type and state, data pattern zones and a data sample timer. The refrigerant type and state are input to the RPFP module 1302. The data pattern zones and data sample timer are input to the pattern analyzer 1304. The RPFP module 1302 determines the saturated vapor temperature based on the refrigerant type and state and the pressure. The superheat monitor 1300 determines the superheat, which is filtered through the pattern analyzer 1304. Output parameters 1310 include an alarm message that is generated by the superheat monitor 1300 based on the filtered superheat signal.

[0072] Referring now to Figure 14, the flood back alert algorithm for the suction side will be described in more detail. In step 1400, P_s and T_s are measured by the suction temperature and pressure sensors 120,118. In step 1402 it is determined whether any compressors for the current rack are running. If no compressors are running, the next rack is checked in step 1404. If a compressor is running, the suction saturation temperature (T_{SSAT}) is determined based on P_s . The superheat is determined based on T_{SSAT} and T_s in step 1408. The superheat is filtered by the pattern analyzer in step 1410. If appropriate, an alarm message is generated in step 1412 and the algorithm ends. Steps 1402 through 1412 are repeated for each rack and steps 1408 through 1412 are repeated for each refrigeration circuit.

[0073] Referring now to Figure 15, the flood back alert algorithm is illustrated for the discharge side. In step 1500, P_d and T_d are measured by the discharge temperature and pressure sensors. In step 1502 it is determined whether any compressors for the current rack are running. If no compressors are running, the next rack is checked in step 1504. If a compressor is running, the discharge saturation temperature (T_{DSAT}) is determined based on P_d in step 1506. The superheat is determined based on T_{DSAT} and T_d in step 1508. The superheat is filtered by the pattern analyzer in step 1510. If appropriate, an alarm message is generated in step 1512 and

the algorithm ends. Steps 1502 through 1512 are repeated for each rack and steps 1508 through 1512 are repeated for each refrigeration circuit.

[0074] Alternative embodiments of the flood back alert algorithm will be described in detail. In a first alternative embodiment, the superheat is compared to a threshold value. If the superheat is greater than or equal to the threshold value then a flood back condition exists. In the event of a flood back condition an alert message is generated.

[0075] More particularly, T_{SAT} is determined by referencing a look-up table using P_s and the refrigerant type. An alarm value (A) and time delay (t) are also provided as presets and may be user selected. An exemplary alarm value is 15° F. The suction superheat (SH_{SUC}) is determined by the difference between T_s and T_{SAT} . An alarm will be signaled if SH_{SUC} is greater than the alarm value for a time period longer than the time delay. This is governed by the following logic:

If $SH_{SUC} > A$ and time $> t$, then alarm

[0076] In another alternative embodiment, the rate of change of T_s is monitored. That is to say, the temperature signal from the temperature sensor 118 is monitored over a period of time. The rate of change is compared to a threshold rate of change. If the rate of change of T_s is greater than or equal to the threshold rate of change, a flood back condition exists.

[0077] The contactor cycling count algorithm monitors the cycling of the various contacts in the refrigeration system 100. The counting mechanism can be one of an internal or an external nature. With respect to internal counting, the refrigeration controller 140 can perform the counting function based on its command signals to operate the various equipment. The refrigeration controller 140 monitors the number of times the particular contact has been cycled (N_{CYCLE}) for a given load. Alternatively, with respect to external counting, a separate current sensor or auxiliary contact can be used to determine N_{CYCLE} . If N_{CYCLE} per hour for the given load is greater than a threshold number of cycles per hour (N_{THRESH}), an alarm is initiated. The value of N_{THRESH} is based on the function of the particular contactor.

[0078] Additionally, N_{CYCLE} can be used to predict when maintenance of the associated equipment or contactor should be scheduled. In one example, N_{THRESH} is associated with the number of cycles after which

maintenance is typically required. Therefore, the alarm indicates maintenance is required on the particular piece of equipment the contact is associated with. Alternatively, N_{CYCLE} can be tracked over time to estimate a point in time when it will achieve N_{THRESH} . A predicative alarm is provided
5 indicating a future point in time when maintenance will be required.

[0079] The cycle count for multiple contactors can be monitored. A group alarm can be provided to indicate predicted maintenance requirements for a group of equipment. The groups include equipment whose N_{CYCLE} count will achieve their respective N_{THRESH} 's within approximately the same time
10 frame. In this manner, the number of maintenance calls is reduced by performing multiple maintenance tasks during a single visit of maintenance personnel.

[0080] Referring now to Figures 16 and 17, the contactor cycling count algorithm will be described with respect to the compressor motor. A
15 contactor cycle monitoring block 1600 includes a measured variable input 1602 and configuration parameter inputs 1604. The contactor cycle monitoring block 1600 processes the measured variable 1602 and the configuration parameters 1604 and generates output parameters 1606. The measured variable includes N_{CYCLE} for the particular compressor and the
20 configuration parameters include a cycle rate limit ($N_{\text{CYCRATELIM}}$) and a cycle maximum (N_{CYCMAX}). The output parameters include a rate exceeded alarm and a maximum exceeded alarm. The rate exceeded alarm is generated when the rate at which the contactor is cycled (N_{CYCRATE}) exceeds $N_{\text{CYCRATELIM}}$. Similarly, the maximum exceeded alarm is generated when N_{CYCLE} exceeds
25 N_{CYCMAX} .

[0081] Figure 17 illustrates steps of the contactor cycling count algorithm. In step 1700 the contactor state (i.e., open or closed) is determined. In step 1702, it is determined whether a state change has occurred. If a state change has not occurred, the algorithm loops back to step
30 1700. If a state change has occurred, N_{CYCLE} is incremented in step 1704. $N_{\text{CYCRATELIM}}$ is determined in step 1708 by dividing N_{CYCLE} by the time over which the closures occurred.

[0082] In step 1710, the algorithm determines whether N_{CYCLE} exceeds N_{CYCMAX} . If N_{CYCLE} does not exceed N_{CYCMAX} , the algorithm

continues in step 1712. If N_{CYCLE} exceeds $N_{\text{CYC}_{\text{MAX}}}$, an alarm is generated in step 1714 and the algorithm continues in step 1712. In step 1712, the algorithm determines whether N_{CYCRATE} exceeds $N_{\text{CYCRATE}_{\text{LIM}}}$. If N_{CYCRATE} does not exceed $N_{\text{CYCRATE}_{\text{LIM}}}$, the algorithm loops back to step 1700. If
5 N_{CYCRATE} exceeds $N_{\text{CYCRATE}_{\text{LIM}}}$, an alarm is generated in step 1716 and the algorithm loops back to step 1700.

[0083] The compressor performance algorithm compares a theoretical compressor energy requirement (E_{THEO}) to an actual measurement of the compressor's energy consumption (E_{ACT}). E_{THEO} is determined based
10 on a model of the compressor. E_{ACT} is directly measured from the energy sensors 150. A difference between E_{THEO} and E_{ACT} is determined and compared to a threshold value (E_{THRESH}). If the absolute value of the difference is greater than E_{THRESH} an alarm is initiated indicating a fault in compressor performance.

15 **[0084]** Referring now to Figures 18 and 19, compressor fault detection algorithm will be described in detail. In general, the compressor fault detection algorithm monitors T_d and determines whether the compressor is operating properly based thereon. T_d reflects the latent heat absorbed in the evaporator, evaporator superheat, suction line heat gain, heat of
20 compression, and compressor motor-generated heat. All of this heat is accumulated at the compressor discharge and must be removed. High compressor T_d 's result in lubricant breakdown, worn rings, and acid formation, all of which shorten the compressor lifespan. This condition can indicate a variety of problems including, but not limited to damaged compressor valves,
25 partial motor winding shorts, excess compressor wear, piston failure and high compression ratios. High compression ratios can be caused by either low P_s , high head pressure, or a combination of the two. The higher the compression ratio, the higher the T_d will be at the compressor. This is due to heat of compression generated when the gasses are compressed through a greater
30 pressure range.

[0085] For each compressor rack with at least one compressor running the discharge saturation temperature (T_{DSAT}) is calculated based on P_d . For each compressor running in the rack SH is calculated by subtracting T_{DSAT} from T_d . The SH data once each minute for 30 minutes using the

pattern analyzer. If the accumulated data indicates an abnormal condition an alarm is generated. Alternatively, T_s and P_s can be monitored and compared to compressor performance curves. For this, a block similar to RPFP and RPFT can be created to perform the performance curve calculations for comparison. Specific deviations from the performance curve would generate maintenance notices.

[0086] With particular reference to Figure 18, a compressor performance monitor block 1800 generates an output parameter 1802 based on measured variables 1804 and configuration parameters 1806. The output parameter 1802 includes an alarm and the measured variable includes T_d and P_d . The configuration parameters include refrigerant type and state and data pattern zones and a data sample timer. The compressor performance monitor block 1800 determines SH and processes SH through the data pattern analyzer and generates the alarm if required.

[0087] Referring now to Figure 19, the compressor fault detection algorithm is illustrated. In step 1900, P_d and T_d are measured by the discharge temperature and pressure sensors. In step 1902, it is determined whether the current rack is running. If the current rack is not running, the algorithm moves to the next rack in step 1904. In step 1906 and 1908, it is determined whether each compressor in the rack is running. In step 1910, T_{DSAT} is determined for the running compressor based on P_d . The superheat is determined based on T_{DSAT} and T_d in step 1912. The superheat is filtered by the pattern analyzer in step 1914. If appropriate, an alarm message is generated in step 1916 and the algorithm loops back to step 1904. Steps 1902 through 1916 are repeated for each rack and steps 1906 through 1916 are repeated for each refrigeration circuit.

[0088] In an alternative embodiment, the compressor fault detection algorithm compares the actual T_d to a calculated discharge temperature (T_{dcalc}). T_d is measured by the temperature sensors 114 associated with the discharge of each compressor 102. Measurements are taken at approximately 10 second intervals while the compressors 102 are running. T_{dcalc} is calculated as a function of the refrigerant type, P_d , suction pressure (P_s) and suction temperature (T_s), each of which are measured by the associated sensors described above. An alarm value (A) and time delay (t)

are also provided as presets and may be user selected. An alarm is signaled if the difference between the actual and calculated discharge temperature is greater than the alarm value for a time period longer than the time delay. This is governed by the following logic:

5 If $(T_d - T_{dcalc}) > A$ and time $> t$, then alarm

10 **[0089]** Dirt and debris gradually builds up on the condenser coil and condenser fans can fail, impairing condenser performance. As these events occur, condenser performance degrades, inhibiting heat transfer to the atmosphere. The condenser performance algorithm is provided to determine whether the condenser 126 is dirty, which would result in a loss of energy efficiency or more serious system problems. Trend data is analyzed over a specified time period (e.g., several days). More specifically, the average difference between the ambient temperature (T_a) and the condensing temperature (T_{COND}) is determined over the time period. If the average difference is greater than a threshold (T_{THRESH}) (e.g., 25°F) a dirty condenser situation is indicated and a maintenance alarm is initiated. T_a is directly measured from the temperature sensor 128.

20 **[0090]** Referring specifically to Figures 20 and 21, another alternative condenser performance algorithm will be described in detail. As illustrated in Figure 20, a condenser performance monitor block 2000 includes an RFPF module 2002 and a pattern analyzer module 2004. The condenser performance monitor block 2000 receives measured variables 2006 and configuration parameters 2008 and generates output parameters 2010 based thereon. The measured variables include T_a , P_c , I_{cmp} and a condenser load (I_{cnd}). The configuration parameters 2008 include refrigerant type and state, data pattern zones and a data sampler timer. The output parameters 2010 include an alarm message.

30 **[0091]** With particular reference to Figure 21, T_a , P_c , I_{cmp} and I_{cnd} are all measured by their respective sensors in step 2100. In step 2102, T_c is determined based on P_c using RFPF, as discussed in detail above. In step 2104, condenser capacity (U) is determined according to the following equation:

$$U = K \frac{I_{CMP}}{(I_{CND} + I_0)(T_c - T_a)}$$

where K is a system constant and I_0 is a calibration value. For example, I_0 can be set equal to 10% of the current consumption when all condenser fans are on. In step 2106, U is processed through the pattern analyzer and an alarm maybe generated in step 2108 based on the results. As U varies from
5 ideal, condenser performance may be impaired and an alarm message will be generated.

[0092] The defrost abnormality algorithm learns the behavior of defrost activity in the refrigeration circuits A, B, C, D. The learned or average defrost behavior is compared to current or past defrost conditions. More
10 specifically, the defrost time (t_{DEF}), maximum defrost time (t_{DEFMAX}) and defrost termination temperature (T_{TERM}) are monitored. If t_{DEF} achieves t_{DEFMAX} for a number of consecutive defrost cycles (N_{DEF}) (e.g., 5 cycles) and the particular case or circuit is set to terminate defrost at T_{TERM} , an abnormal defrost situation is indicated. An alarm is initiated accordingly. The defrost
15 abnormality algorithm also monitors T_{TERM} across cases within a circuit to isolate cases having the highest T_{TERM} .

[0093] The case discharge versus product temperature algorithm compares the air discharge temperature ($T_{DISCHARGE}$) to the case's set point temperature ($T_{SETPOINT}$) and the product temperature (T_{PROD}) to $T_{DISCHARGE}$.
20 The case temperature (T_{CASE}) is also monitored. If $T_{DISCHARGE}$ is equal to $T_{SETPOINT}$, and T_{PROD} is greater than T_{CASE} plus a tolerance temperature (T_{TOL}) a problem with the case is indicated. An alarm is initiated accordingly.

[0094] Refrigerant level within the refrigeration system 100 is a function of refrigeration load, ambient temperatures, defrost status, heat
25 reclaim status and refrigerant charge. A reservoir level indicator (not shown) reads accurately when the system is running and stable and it varies with the cooling load. When the system is turned off, refrigerant pools in the coldest parts of the system and the level indicator may provide a false reading. The refrigerant loss detection algorithm determines whether there is leakage in the
30 refrigeration system 100. The liquid refrigerant level in an optional receiver (not shown) is monitored. The receiver would be disposed between the condenser 126 and the individual circuits A, B, C, D. If the liquid refrigerant level in the receiver drops below a threshold level, a loss of refrigerant is indicated and an alarm is initiated.

[0100] Referring now to Figures 22 through 24, the data pattern recognition algorithm monitors inputs such as T_{CASE} , T_{PROD} , P_s and P_d . The algorithm includes a data table (see Figure 22) having multiple bands whose upper and lower limits are defined by configuration parameters. A particular
5 input is measured at a configured frequency (e.g., every minute, hour, day, etc.). as the input value changes, the algorithm determines within which band the value lies and increments a counter for that band. After the input has been monitored for a specified time period (e.g., a day, a week, a month, etc.) alarms are generated based on the band populations. The bands are defined
10 by various boundaries including a high positive (PP) boundary, a positive (P) boundary, a zero (Z) boundary, a minus (M) boundary and a high minus (MM) boundary. The number of bands and the boundaries thereof are determined based on the particular refrigeration system operating parameter to be monitored. For each reading a corresponding band is populated. If the
15 population of a particular band exceeds an alarm limit, a corresponding alarm is generated.

[0101] Referring now to Figure 23, a pattern analyzer block 2500 receives measured variables 2502, configuration parameters 2504 and generates output parameters 2506 based thereon. The measured variables
20 2502 include an input (e.g., T_{CASE} , T_{PROD} , P_s and P_d). The configuration parameters 2504 include a data sample timer and data pattern zone information. The data sample timer includes a duration, an interval and a frequency. The data pattern zone information defines the bands and which bands are to be enabled. For example, the data pattern zone information
25 provides the boundary values (e.g., PP) band enablement (e.g., PPen), band value (e.g., PPband) and alarm limit (e.g., PPpct).

[0102] Referring now to Figure 26, input registers are set for measurement and start trigger in step 2600. In step 2602, the algorithm determines whether the start trigger is present. If the start trigger is not
30 present, the algorithm loops back to step 2600. If the start trigger is present, the pattern table is defined in step 2604 based on the data pattern bands. In step 2606, the pattern table is cleared. In step 2608, the measurement is read and the measurement data is assigned to the pattern table in step 2610.

[0103] In step 2612, the algorithm determines whether the duration has expired. If the duration has not yet expired, the algorithm waits for the defined interval in step 2614 and loops back to step 2608. If the duration has expired, the algorithm populates the output table in step 2616. In
5 step 2618, the algorithm determines whether the results are normal. In other words, the algorithm determines whether the population of a each band is below the alarm limit for that band. If the results are normal, messages are cleared in step 2620 and the algorithm ends. If the results are not normal, the algorithm determines whether to generate a notification or an alarm in step
10 2622. In step 2624, the alarm or notification message(s) is/are generated and the algorithm ends.

[0104] The description of the invention is merely exemplary in nature and, thus, variations that do not depart from the gist of the invention are intended to be within the scope of the invention. Such variations are not
15 to be regarded as a departure from the spirit and scope of the invention.

AMENDED CLAIMS

[received by the International Bureau on 05 January 2005 (05.01.2005);
original claims 1, 2, 15, 16, 29 and 42 amended; remaining claims unchanged]

What is claimed is:

1. A system for monitoring a remote refrigeration system, the system comprising:
 - 5 a plurality of sensors that monitor parameters of components of said refrigeration system;
 - a communication network that transfers signals generated by each of said plurality of sensors; and
 - a management center processing said signals from said communication network, categorizing said signals, and evaluating a distribution among categories, to determine an operating condition of at least one of said components.
- 15 2. The system of claim 1, wherein said processing of said signals includes determining whether each of said signals is within a useful range, determining whether each of said signals is dynamic and determining whether each of said signals is valid.
3. The system of claim 1, further comprising a temperature sensor that monitors a temperature of a refrigerant flowing through said refrigeration system and that generates a temperature signal.
- 20 4. The system of claim 3, wherein said management center calculates a pressure, a density and an enthalpy of said refrigerant based on said temperature and based on whether said refrigerant is in one of a saturated liquid phase and a saturated vapor phase.
5. The system of claim 1, further comprising a pressure sensor that monitors a pressure of a refrigerant flowing through said refrigeration system and that generates a pressure signal.
- 25 6. The system of claim 5, wherein said management center calculates a temperature, a density and an enthalpy of said refrigerant based on said pressure and based on whether said refrigerant is in one of a saturated liquid phase and a saturated vapor phase.
- 30 7. The system of claim 1, further comprising:
 - a temperature sensor that monitors a temperature of a refrigerant at a suction side of a compressor of said refrigeration system and that generates a temperature signal; and

a pressure sensor that monitors a pressure of a refrigerant at said suction side of said compressor and that generates a pressure signal;

wherein said management center determines an occurrence of a floodback event based on said temperature signal and said pressure signal.

5 8. The system of claim 7, wherein said management center determines a superheat temperature of said refrigerant based on said temperature signal and said pressure signal and observes a pattern of said superheat over a time period to determine whether said floodback event has occurred.

10 9. The system of claim 1, further comprising:

a temperature sensor that monitors a temperature of a refrigerant at a discharge side of a compressor of said refrigeration system and that generates a temperature signal; and

15 a pressure sensor that monitors a pressure of a refrigerant at said discharge side of said compressor and that generates a pressure signal;

wherein said management center determines an occurrence of a floodback event based on said temperature signal and said pressure signal.

20 10. The system of claim 9, wherein said management center determines a superheat temperature of said refrigerant based on said temperature signal and said pressure signal observes a pattern of said superheat over a time period to determine whether said floodback event has occurred.

25 11. The system of claim 1, further comprising a contactor associated with one of said components and that is cycled between an open position and a closed position to selectively operate said component.

12. The system of claim 11, wherein said management center monitors cycling of said contactor and generates an alarm when one of a cycling rate is exceeded and a maximum number of cycles is exceeded.

30 13. The system of claim 1, further comprising:
an ambient condenser temperature sensor that generates an ambient temperature signal;

a condenser pressure sensor that generates a pressure signal;

a compressor current sensor that generates a compressor current signal; and

a condenser current sensor that generates a condenser current signal;
wherein said management center determines an operating condition of
said condenser based on said ambient temperature signal, said pressure
signal, said compressor current signal and said condenser current signal.

5 14. The system of claim 13, wherein said management center
determines a power consumption of said condenser, observes said power
consumption over a period of time and selectively generates an alarm based
on a pattern of said power consumption.

10 15. A method monitoring a refrigeration system at a remote location,
comprising the steps of:

generating signals from a plurality of sensors that monitor parameters
of components of said refrigeration system;

transferring signals generated by each of said plurality of sensors over
a communication network;

15 processing said signals;

categorizing said signals; and

evaluating a distribution among categories to determine an operating
condition of at least one of said components.

20 16. The method of claim 15, wherein said processing of said signals
includes determining whether each of said signals is within a useful range,
determining whether each of said signals is dynamic and determining whether
each of said signals is valid.

25 17. The method of claim 15, further comprising:
monitoring a temperature of a refrigerant flowing through said
refrigeration system; and

generating a temperature signal based on said temperature.

30 18. The method of claim 17, further comprising calculating a
pressure, a density and an enthalpy of said refrigerant based on said
temperature and based on whether said refrigerant is in one of a saturated
liquid phase and a saturated vapor phase.

19. The method of claim 15, further comprising:
monitoring a pressure of a refrigerant flowing through said refrigeration
system; and

generating a pressure signal based on said pressure.

20. The method of claim 19, further comprising calculating a temperature, a density and an enthalpy of said refrigerant based on said pressure and based on whether said refrigerant is in one of a saturated liquid phase and a saturated vapor phase.

5 21. The method of claim 15, further comprising:
monitoring a temperature of a refrigerant at a suction side of a compressor of said refrigeration system;
generating a temperature signal based on said temperature;
monitoring a pressure of a refrigerant at said suction side of said
10 compressor;
generating a pressure signal based on said pressure; and
determining an occurrence of a floodback event based on said temperature signal and said pressure signal.

22. The method of claim 21, further comprising:
15 determining a superheat temperature of said refrigerant based on said temperature signal and said pressure signal; and
observing a pattern of said superheat over a time period to determine whether said floodback event has occurred.

23. The system of claim 15, further comprising:
20 monitoring a temperature of a refrigerant at a discharge side of a compressor of said refrigeration system;
generating a temperature signal based on said temperature; and
monitoring a pressure of a refrigerant at said discharge side of said compressor;
25 generating a pressure signal based on said pressure; and
determining an occurrence of a floodback event based on said temperature signal and said pressure signal.

24. The method of claim 23, further comprising:
determining a superheat temperature of said refrigerant based on said
30 temperature signal and said pressure signal; and
observing a pattern of said superheat over a time period to determine whether said floodback event has occurred.

25. The method of claim 15, further comprising a cycling a contactor associated with one of said components between an open position and a closed position to selectively operate said component.

26. The method of claim 25, further comprising:
5 monitoring said cycling of said contactor; and
generating an alarm when one of a cycling rate is exceeded and a maximum number of cycles is exceeded.

27. The method of claim 15, further comprising:
generating an ambient temperature signal based on an ambient air
10 temperature of a condenser;
generating a pressure signal based on a condenser pressure;
generating a compressor current signal based on a compressor current;
generating a condenser current signal based on a condenser current;
15 and
determining an operating condition of said condenser based on said ambient temperature signal, said pressure signal, said compressor current signal and said condenser current signal.

28. The method of claim 27, further comprising:
20 determining a power consumption of said condenser;
observing said power consumption over a period of time; and
selectively generating an alarm based on a pattern of said power consumption.

29. A system for monitoring a remote refrigeration system, the
25 system comprising:
a plurality of sensors that monitor parameters of components of said refrigeration system;
a communication network that transfers signals generated by each of said plurality of sensors; and
30 a management center that receives said signals from said communication network, said management center processing said signals to determine an operating condition of at least one of said components, monitoring a distribution of said signals over time and determining an operating condition based on said distribution.

30. The system of claim 29, wherein said management center determines a plurality of bands that define ranges associated with each of said signals and populates each band based on values of said signals that are observed over a defined time period.

5 31. The system of claim 30, wherein an alarm is generated when a population of a particular band exceeds a threshold associated with said particular band.

32. The system of claim 29, wherein said management center evaluates each of said signals to determine whether each of said signals is
10 within a useful range, to determine whether each of said signals is dynamic and to determine whether each of said signals is valid.

33. The system of claim 29, further comprising a temperature sensor that monitors a temperature of a refrigerant flowing through said refrigeration system and that generates a temperature signal.

15 34. The system of claim 33, wherein said management center calculates a pressure, a density and an enthalpy of said refrigerant based on said temperature and based on whether said refrigerant is in one of a saturated liquid phase and a saturated vapor phase.

35. The system of claim 29, further comprising a pressure sensor
20 that monitors a pressure of a refrigerant flowing through said refrigeration system and that generates a pressure signal.

36. The system of claim 35, wherein said management center calculates a temperature, a density and an enthalpy of said refrigerant based on said pressure and based on whether said refrigerant is in one of a
25 saturated liquid phase and a saturated vapor phase.

37. The system of claim 29, further comprising:

a temperature sensor that monitors a temperature of a refrigerant at a suction side of a compressor of said refrigeration system and that generates a temperature signal; and

30 a pressure sensor that monitors a pressure of a refrigerant at said suction side of said compressor and that generates a pressure signal;

wherein said management center determines an occurrence of a floodback event based on said temperature signal and said pressure signal.

38. The system of claim 37, wherein said management center determines a superheat temperature of said refrigerant based on said temperature signal and said pressure signal and observes a pattern of said superheat over a time period to determine whether said floodback event has
5 occurred.

39. The system of claim 29, further comprising:

a temperature sensor that monitors a temperature of a refrigerant at a discharge side of a compressor of said refrigeration system and that generates a temperature signal; and

10 a pressure sensor that monitors a pressure of a refrigerant at said discharge side of said compressor and that generates a pressure signal;

wherein said management center determines an occurrence of a floodback event based on said temperature signal and said pressure signal.

40. The system of claim 39, wherein said management center
15 determines a superheat temperature of said refrigerant based on said temperature signal and said pressure signal observes a pattern of said superheat over a time period to determine whether said floodback event has occurred.

41. The system of claim 29, further comprising:

20 an ambient condenser temperature sensor that generates an ambient temperature signal;

a condenser pressure sensor that generates a pressure signal;

a compressor current sensor that generates a compressor current signal; and

25 a condenser current sensor that generates a condenser current signal;

wherein said management center determines an operating condition of said condenser based on said ambient temperature signal, said pressure signal, said compressor current signal and said condenser current signal.

42. A method of monitoring a remote refrigeration system,
30 comprising:

generating signals from a plurality of sensors that monitor parameters of components of said refrigeration system;

transferring signals generated by each of said plurality of sensors over a communication network;

processing said signals;
monitoring a distribution of said signals over time; and
determining an operating condition of at least one of said components
based on said distribution.

5 43. The method of claim 42, further comprising:
determining a plurality of bands that define ranges associated with
each of said signals; and

populating each band based on values of said signals that are
observed over a defined time period.

10 44. The method of claim 43, further comprising generating an alarm
when a population of a particular band exceeds a threshold associated with
said particular band.

15 45. The method of claim 42, further comprising evaluating each of
said signals to determine whether each of said signals is within a useful
range, to determine whether each of said signals is dynamic and to determine
whether each of said signals is valid.

20 46. The method of claim 42, further comprising:
monitoring a temperature of a refrigerant flowing through said
refrigeration system; and
generating a temperature signal based on said temperature.

47. The method of claim 46, further comprising calculating a
pressure, a density and an enthalpy of said refrigerant based on said
temperature and based on whether said refrigerant is in one of a saturated
liquid phase and a saturated vapor phase.

25 48. The method of claim 42, further comprising:
monitoring a pressure of a refrigerant flowing through said refrigeration
system; and
generating a pressure signal based on said pressure.

30 49. The method of claim 48, further comprising calculating a
temperature, a density and an enthalpy of said refrigerant based on said
pressure and based on whether said refrigerant is in one of a saturated liquid
phase and a saturated vapor phase.

50. The method of claim 42, further comprising:

monitoring a temperature of a refrigerant at a suction side of a compressor of said refrigeration system;

generating a temperature signal based on said temperature;

5 monitoring a pressure of a refrigerant at said suction side of said compressor;

generating a pressure signal based on said pressure; and

determining an occurrence of a floodback event based on said temperature signal and said pressure signal.

51. The method of claim 50, further comprising:

10 determining a superheat temperature of said refrigerant based on said temperature signal and said pressure signal; and

observing a pattern of said superheat over a time period to determine whether said floodback event has occurred.

52. The system of claim 42, further comprising:

15 monitoring a temperature of a refrigerant at a discharge side of a compressor of said refrigeration system;

generating a temperature signal based on said temperature; and

monitoring a pressure of a refrigerant at said discharge side of said compressor;

20 generating a pressure signal based on said pressure; and

determining an occurrence of a floodback event based on said temperature signal and said pressure signal.

53. The method of claim 52, further comprising:

25 determining a superheat temperature of said refrigerant based on said temperature signal and said pressure signal; and

observing a pattern of said superheat over a time period to determine whether said floodback event has occurred.

54. The method of claim 42, further comprising:

30 generating an ambient temperature signal based on an ambient air temperature of a condenser;

generating a pressure signal based on a condenser pressure;

generating a compressor current signal based on a compressor current;

generating a condenser current signal based on a condenser current;
and

determining an operating condition of said condenser based on said
ambient temperature signal, said pressure signal, said compressor current
5 signal and said condenser current signal.

55. The method of claim 54, further comprising:
determining a power consumption of said condenser;
observing said power consumption over a period of time; and
selectively generating an alarm based on a pattern of said power
10 consumption.

1/24




FIG 1

2/24




FIG 2

3/24




FIG 3

4/24




FIG 4

5/24




FIG 5

6/24




FIG 6

7/24




FIG 7

8/24




FIG 8

9/24




FIG 9

10/24




FIG 10

11/24




FIG 11

12/24




FIG 12

13/24




FIG 13

14/24




FIG 14

15/24




FIG 15

16/24




FIG 16

17/24




FIG 17

18/24




FIG 18

19/24




FIG 19

20/24




FIG 20

21/24




FIG 21




FIG 22




FIG 23

24/24




FIG 24

